

O.E.P.A.
S.E.D.O.

2008 JUL 11 AM 9:30

43521 Mayhugh Hill Road
Twp.Hwy.88
Beallsville, Ohio 43716
Phone: (740) 926-9152
FAX: (740) 926-9138

American Energy Corporation

July 10, 2008

Ohio EPA
State of Ohio Environmental Protection Agency
Southeast District Office
2195 Front Street
Logan, OH 43183

Attention: Abbot Stevenson

Dear Ms. Abbot Stevenson:

We are in receipt of the Ohio EPA letter dated June 30th, 2008 concerning the Discharge Monitoring Report covering the months of September 2007 through May 2008. Please find listed below our proposed corrections to outfall 17 and 15.

- **Outfall 017 (Nitrogen, Ammonia, (NH₃) Dissolved Oxygen, CBOD 5 Day) -** I have discussed the corrections with our Class 1 WasteWater operator. Since the problem parameters relate to aeration; we will increase the cycle times to the aeration system which will provide additional oxygen to the system. We believe this correction will bring the system back into compliance. We will continue to monitor the system and make any additional changes necessary.
- **Outfall 015 (Manganese, Total) –** We cleaned pond 15 and have increased the sodash application. This should bring the Manganese in compliance. The pond is due to be cleaned again in August 2008.

If you have any questions or need additional information please feel free to contact me at your convenience.

.....